

# 1SP0335x2x1-CM900HG-90H and 1SP0335x2x1C-CM900HG-90H Data Sheet

Compact, high-performance, plug-and-play single-channel IGBT driver based on SCALE™-2 technology for individual and parallel-connected modules in 2-level, 3-level and multilevel converter topologies

#### **Abstract**

The SCALE<sup>TM</sup>-2 plug-and-play driver 1SP0335x2x1-CM900HG-90H / 1SP0335x2x1C-CM900HG-90H (Coated version using ELPEGUARD SL 1307 FLZ/2 from Lackwerke Peters with a typical thickness of  $50\mu m$ ) is a compact single-channel intelligent gate driver designed for Mitsubishi's IGBTs CM900HG-90H. The master driver 1SP0335x2M1(C)-CM900HG-90H features a fiber-optic interface. It can be used as stand-alone driver or in conjunction with up to three 1SP0335D2S1(C)-CM900HG-90H slaves to drive up to four parallel-connected IGBT modules of type CM900HG-90H.

The DC/DC power supply must be purchased as a separate unit (one per master driver).

For drivers adapted to other types of high-power and high-voltage IGBT modules, refer to:

www.power.com/gate-driver/go/plug-and-play

#### Features

- ✓ Plug-and-play solution
- ✓ Allows parallel connection of IGBT modules
- ✓ For 2-level, 3-level and multilevel topologies
- ✓ Fiber-optic links (master)
- ✓ Built-in interface to 1SP0335D2S1 (slave)
- ✓ Duty cycle 0...100%
- ✓ Dynamic Advanced Active Clamping DA<sup>2</sup>C
- ✓ Dynamic IGBT short-circuit protection
- ✓ Monitoring of supply voltage
- Monitoring of gate voltage
- ✓ Extremely reliable; long service life
- ✓ Shortens application development time
- ✓ Suitable for CM900HG-90H

### **Applications**

- ✓ Traction
- ✓ Railroad power supplies
- Light rail vehicles
- ✓ HVDC
- ✓ Flexible AC transmission systems (FACTS)
- ✓ Medium-voltage converters
- ✓ Industrial drives
- ✓ Wind-power converters
- ✓ Medical applications
- ✓ Research
- ✓ And many others



#### Safety Notice!

The data contained in this data sheet is intended exclusively for technically trained staff. Handling all high-voltage equipment involves risk to life. Strict compliance with the respective safety regulations is mandatory!

Any handling of electronic devices is subject to the general specifications for protecting electrostatic-sensitive devices according to international standard IEC 60747-1, Chapter IX or European standard EN 100015 (i.e. the workplace, tools, etc. must comply with these standards). Otherwise, this product may be damaged.

#### **Important Product Documentation**

This data sheet contains only product-specific data. For a detailed description, must-read application notes and common data that apply to the whole series, please refer to the "Description & Application Manual for 1SP0335 SCALE-2 IGBT Drivers" on <a href="https://www.power.com/gate-driver/qo/1SP0335">www.power.com/gate-driver/qo/1SP0335</a>.

When applying SCALE-2 plug-and-play drivers, please note that these drivers are specifically adapted to a particular type of IGBT module. Therefore, the type designation of SCALE-2 plug-and-play drivers also includes the type designation of the corresponding IGBT module. These drivers are not valid for IGBT modules other than those specified. Incorrect use may result in failure.

#### **Mechanical Dimensions**

Dimensions: Refer to the relevant "Description and Application Manual"

Mounting principle: Connected to IGBT module with screws

### Fiber-Optic Interfaces (1SP0335x2M1(C))

Interface	Remarks	Part type #
Drive signal input Drive signal input Status output	1SP0335V, fiber-optic receiver (Notes 1, 2) 1SP0335S, fiber-optic receiver (Notes 1, 2) 1SP0335V, fiber-optic transmitter (Notes 1, 3)	HFBR-2522ETZ HFBR-2412Z HFBR-1522ETZ HFBR-1412Z
Status output	1SP0335S, fiber-optic transmitter (Notes 1, 3)	HFBK-1412Z

#### **Electrical Connectors**

Interface	Remarks	Part type #
Power supply connector X1 Bus connectors X2 and X3	On-board connector (Note 4) On-board connectors (Note 5)	214012 214013



### **Absolute Maximum Ratings**

Parameter	Remarks	Min	Max	Unit
Supply voltage V <sub>DC</sub>	VDC to COM	0	30	V
Average supply current I <sub>DC</sub>	1SP0335x2M1(C) only (Note 6)		215	mA
Average supply current I <sub>DC</sub>	1SP0335x2M1(C) with three 1SP0335D2S1 (Note 6)		740	mA
Gate output power	1SP0335x2M1(C), Ta < 70°C (Note 7)		3.5	W
	$1SP0335x2M1(C)$ , Ta = $85^{\circ}C$ (Note 7)		2.5	W
Gate output power	1SP0335D2S1(C), Ta < 70°C (Note 8)		3.3	W
	1SP0335D2S1(C), Ta = 85°C (Note 8)		2.3	W
Switching frequency f	1SP0335x2M1(C), Ta < 70°C		11	kHz
	$1SP0335x2M1(C)$ , Ta = $85^{\circ}C$		7.5	kHz
Switching frequency f	1SP0335D2S1(C), Ta < 70°C		10.1	kHz
	1SP0335D2S1(C), Ta = 85°C		7	kHz
Gate peak current Iout	Note 9	-35	+35	Α
DC-link voltage	Switching operation (Note 10)		3000	V
	Off state (Note 11)		3550	V
Operating voltage	Collector-emitter voltage		4500	$V_{\text{peak}}$
Max. emitter-emitter voltage	Between parallel connected drivers (Note 12)		200	$V_{\text{peak}}$
dV/dt	Between parallel connected drivers (Note 13)		50	kV/μs
Max. interface current	X2 and X3, total RMS value (Note 14)		4	$A_{\text{rms}}$
	X2 and X3, total peak value (Note 14)		20	$A_{\text{peak}}$
Operating temperature		-40	85	°C
Storage temperature	Note 28	-40	50	°C
Surface temperature	Only 1SP0335x2x1C-CM900HG-90H (Note 29)		125	°C

### **Recommended Operating Conditions**

Power Supply	Remarks	Min	Тур	Max	Unit
Supply voltage V <sub>DC</sub>	To COM	23.5	25	26.5	V



### **Electrical Characteristics**

All data refer to  $+25^{\circ}\text{C}$  and  $V_{\text{DC}} = 25\text{V}$  unless otherwise specified

Supply threshold V <sub>Iso</sub> -V <sub>ee</sub>	Power Supply	Remarks	Min	Тур	Max	Unit
Nonitoring   Remarks   Min   Typ   Max   Use   Monitoring   Supply threshold Viso-Vee   Clear fault   Set fault (Note 15)   11.5   12.0   12.5	Supply current I <sub>DC</sub>	Without load, only 1SP0335x2M1(C)		45		mA
Supply threshold V <sub>Iso</sub> -V <sub>ee</sub>   Clear fault   Set fault (Note 15)   11.5   12.0   12.5		Without load, per additional 1SP0335D2S1(C)		20		mA
Set fault (Note 15) 11.5 12.0 12.5 Monitoring hysteresis Set/clear fault 0.35 Supply threshold Vee-VcoM Clear fault 5 5.15 5.3 Set fault (Note 15) 4.7 4.85 5 Monitoring hysteresis Set/clear fault 0.15	Power Supply Monitoring	Remarks	Min	Тур	Max	Unit
Monitoring hysteresis Supply threshold Vee-VcoM Clear fault Set fault (Note 15) Monitoring hysteresis Set/clear fault Set fault (Note 15) Monitoring hysteresis Set/clear fault  O.15  Bus to 1SP0335D2S1(C) Remarks Min Typ Max Command To COM Turn-off command To COM To COM To COM Turn-on command To COM Turn-on threshold VGE,on,min Turn-on threshold VGE,on,min Turn-off threshold VGE,off,max Gmean to E, set fault (Note 16) Turn-off (Note 16)	Supply threshold V <sub>iso</sub> -V <sub>ee</sub>	Clear fault	12.1	12.6	13.1	٧
Supply threshold Vee-VcoM Set fault (Note 15) Set fault (Note 15) A.7 A.85 Set fault (Note 16) A.7 A.85 A.7 A.85 A.7 A.85 A.7 A.85 A.7 A.85 A.85 A.85 A.85 A.85 A.85 A.85 A.85		Set fault (Note 15)	11.5	12.0	12.5	V
Set fault (Note 15)	Monitoring hysteresis	Set/clear fault	0.35			V
Monitoring hysteresis  Bus to 1SP0335D2S1(C)  Remarks  Min Typ Max U  Supply voltage Turn-off command To COM Turn-on command To COM Turn-on command To COM Turn-on threshold V <sub>GE,on,min</sub> Turn-off threshold V <sub>GE,off,max</sub> Filter delay  Short-circuit Protection  Remarks  Set/clear fault O.15  Min Typ Max U  Comman to E, set fault (Note 16) Turn-off (Note 17) Torn-off (Note 17) Torn-off (Note 18) Turn-off (Note 18)	Supply threshold V <sub>ee</sub> -V <sub>COM</sub>	Clear fault	5	5.15	5.3	V
Bus to 1SP0335D2S1(C)  Remarks  Min Typ Max C  Supply voltage Turn-off command To COM Turn-on command To COM Turn-on command To COM Turn-on threshold V <sub>GE,on,min</sub> Turn-on threshold V <sub>GE,on,min</sub> Turn-off threshold V <sub>GE,on,min</sub> Gmean to E, set fault (Note 16) Turn-off threshold V <sub>GE,off,max</sub> Gmean to E, set fault (Note 16) Turn-off (Note 16) Turn-off (Note 16) Turn-off (Note 16) Turn-off (Note 16) Short-circuit Protection Remarks  Min Typ Max C  Static Vce-monitoring threshold Response time  Between auxiliary terminals (Note 17) DC-link voltage = 3000V (Note 18)  5.8		Set fault (Note 15)	4.7	4.85	5	V
Supply voltage Turn-off command To COM Turn-on command To COM Turn-on command To COM Turn-on threshold V <sub>GE,on,min</sub> Turn-on threshold V <sub>GE,on,min</sub> Turn-off threshold V <sub>GE,off,max</sub> Filter delay  Short-circuit Protection  Remarks  Min Typ Max U  Turn-off (Note 16)	Monitoring hysteresis	Set/clear fault	0.15			V
Turn-off command To COM Turn-on command To COM Turn-on command To COM To	Bus to 1SP0335D2S1(C)	Remarks	Min	Тур	Max	Unit
Turn-on command  To COM  Remarks  Min Typ Max U  Turn-on threshold V <sub>GE,on,min</sub> Turn-off threshold V <sub>GE,off,max</sub> Filter delay  Short-circuit Protection  Remarks  Min Typ Max U  12.9  Gmean to E, set fault (Note 16)  Turn-on (Note 16)  Turn-on (Note 16)  Turn-off (Note 16)  Short-circuit Protection  Remarks  Min Typ Max U  Static Vce-monitoring threshold  Response time  Between auxiliary terminals (Note 17)  DC-link voltage = 3000V (Note 18)  5.8	Supply voltage			VDC		V
Gate MonitoringRemarksMinTypMaxUnit of the shold VGE,on,minTurn-on threshold VGE,on,minGmean to E, set fault (Note 16)12.9Turn-off threshold VGE,off,maxGmean to E, set fault (Note 16)-7.6Filter delayTurn-on (Note 16)28Turn-off (Note 16)42Short-circuit ProtectionRemarksMinTypMaxStatic Vce-monitoring threshold Response timeBetween auxiliary terminals (Note 17)170DC-link voltage = 3000V (Note 18)5.8	Turn-off command	To COM		0		V
Turn-on threshold V <sub>GE,on,min</sub> Gmean to E, set fault (Note 16) 12.9 Turn-off threshold V <sub>GE,off,max</sub> Gmean to E, set fault (Note 16) 7-7.6 Filter delay Turn-on (Note 16) 28 Turn-off (Note 16) 42  Short-circuit Protection Remarks Min Typ Max U Static Vce-monitoring threshold Response time Between auxiliary terminals (Note 17) DC-link voltage = 3000V (Note 18) 5.8	Turn-on command	To COM		15		V
Turn-off threshold V <sub>GE,off,max</sub> Filter delay  Turn-on (Note 16)  Turn-off (Note 16)  Short-circuit Protection  Remarks  Min  Typ  Max  U  Static Vce-monitoring threshold Response time  Between auxiliary terminals (Note 17) DC-link voltage = 3000V (Note 18)  5.8	Gate Monitoring	Remarks	Min	Тур	Max	Unit
Turn-off threshold V <sub>GE,off,max</sub> Filter delay  Turn-on (Note 16)  Turn-off (Note 16)  Short-circuit Protection  Remarks  Min  Typ  Max  U  Static Vce-monitoring threshold Response time  Remarks  Between auxiliary terminals (Note 17)  DC-link voltage = 3000V (Note 18)  5.8	Turn-on threshold V <sub>GE,on,min</sub>	G <sub>mean</sub> to E, set fault (Note 16)		12.9		V
Turn-off (Note 16)  Short-circuit Protection  Remarks  Min Typ Max U  Static Vce-monitoring threshold Response time  Between auxiliary terminals (Note 17) 170 DC-link voltage = 3000V (Note 18) 5.8	Turn-off threshold V <sub>GE,off,max</sub>	G <sub>mean</sub> to E, set fault (Note 16)		-7.6		V
Short-circuit ProtectionRemarksMinTypMaxUStatic Vce-monitoring threshold Response timeBetween auxiliary terminals (Note 17) DC-link voltage = 3000V (Note 18)170 5.8	Filter delay	Turn-on (Note 16)		28		μs
Static Vce-monitoring threshold Between auxiliary terminals (Note 17) 170 Response time DC-link voltage = 3000V (Note 18) 5.8	·	Turn-off (Note 16)		42		μs
Response time DC-link voltage = 3000V (Note 18) 5.8	Short-circuit Protection	Remarks	Min	Тур	Max	Unit
·	Static Vce-monitoring threshold	Between auxiliary terminals (Note 17)		170		V
DC-link voltage = 2000V (Note 18) 5.8	Response time	DC-link voltage = 3000V (Note 18)		5.8		μs
Do min voltage 2000 (Note 10)		DC-link voltage = 2000V (Note 18)		5.8		μs
DC-link voltage = $1500V$ (Note 18) 6.0		DC-link voltage = 1500V (Note 18)		6.0		μs
DC-link voltage = $1000V$ (Note 18) 7.7		DC-link voltage = 1000V (Note 18)		7.7		μs
Delay to IGBT turn-off After the response time (Note 19) 0.3	Delay to IGBT turn-off	After the response time (Note 19)		0.3		μs
Timing Characteristics Remarks Min Typ Max U	Timing Characteristics	Remarks	Min	Тур	Max	Unit
Turn-on delay t <sub>d(on)</sub> Note 20 190	Turn-on delay t <sub>d(on)</sub>	Note 20		190		ns
Turn-off delay t <sub>d(off)</sub> Note 20 185	• • •					ns
Output rise time $t_{r(out)}$ G to E (Note 21) 9	• • • •	G to E (Note 21)				ns
Output fall time $t_{f(out)}$ G to E (Note 21) 30				30		ns



Timing Characteristics	Remarks	Min	Тур	Max	Unit
Transmission delay of fault state	Note 22		90		ns
Delay to clear fault state	After IGBT short circuit (Note 23)		9		μs
	After gate-monitoring fault (Notes 23, 27)		1		μs
Acknowledge delay time	Note 24		250		ns
Acknowledge pulse width	On host side	400	700	1050	ns
Gate Output	Remarks	Min	Тур	Max	Unit
Turn-on gate resistor R <sub>g(on)</sub>	Note 25		10.2		Ω
Turn-off gate resistor R <sub>g(off)</sub>	Note 25		12.3		Ω
Auxiliary gate capacitor Cge		not	assemb	oled	nF
Gate voltage at turn-on	Note 26		15		V
Gate-voltage at turn-off	Note 26		-10		V

#### **Footnotes to the Key Data**

- 1) The transceivers required on the host controller side are not supplied with the gate driver. It is recommended to use the same types as used in the gate driver. For product information refer to <a href="https://www.power.com/gate-driver/go/fiberoptics">www.power.com/gate-driver/go/fiberoptics</a>.
- 2) The recommended transmitter current at the host controller is 20mA. A higher current may increase jitter or delay at turn-off.
- 3) The typical transmitter current at the gate driver is 18mA. In case of supply undervoltage, the minimum transmitter current at the gate driver is 12mA: this is suitable for adequate plastic optical fibers with a length of up to 10 meters.
- 4) This refers to the manufacturer ordering number, see <a href="www.power.com/gate-driver/go/ext\_erni">www.power.com/gate-driver/go/ext\_erni</a>. The customer-side connector as well as cables with different lengths can be supplied by Power Integrations. Refer to the "Description & Application Manual for 1SP0335 SCALE-2 IGBT Drivers" for more information.
- 5) This refers to the manufacturer ordering number, see <a href="www.power.com/gate-driver/go/ext erni">www.power.com/gate-driver/go/ext erni</a>. These connectors are to be used to connect 1SP0335x2M1(C) (master) or 1SP0335D2S1(C) (slave) to 1SP0335D2S1(C) (slave) if parallel connection of IGBT modules is required. Cables with different lengths can be supplied by Power Integrations. Refer to the "Description & Application Manual for 1SP0335 SCALE-2 IGBT Drivers" for more information.
- 6) If the specified value is exceeded, this indicates a driver overload. It should be noted that the driver is not protected against overload.
- 7) The given power can only be fully exploited without slaves 1SP0335D2S1(C) (no parallel connection of IGBT modules). If the specified value is exceeded, this indicates a driver overload. It should be noted that the driver is not protected against overload. From 70°C to 85°C, the maximum permissible output power can be linearly interpolated from the given data.
- 8) The given power can be fully exploited with slaves 1SP0335D2S1(C) (parallel connection of IGBT modules). If the specified value is exceeded, this indicates a driver overload. It should be noted that the driver is not protected against overload. From 70°C to 85°C, the maximum permissible output power can be linearly interpolated from the given data.
- 9) The gate current is limited by the gate resistors located on the driver.
- 10) This limit is due to active clamping under switching conditions. Refer to the "Description & Application Manual for 1SP0335 SCALE-2 IGBT Drivers".
- 11) Due to the Dynamic Active Advanced Clamping Function (DA<sup>2</sup>C) implemented on the driver, the DC-link voltage can be increased in the off-state condition (e.g. after emergency shut-down). This value is only valid when the IGBTs are in the off state (not switching). The time during which the voltage can be applied should be limited to short periods (< 60 seconds). Refer to the "Description & Application Manual for 1SP0335 SCALE-2 IGBT Drivers".



- 12) The maximum dynamic voltage between auxiliary emitters of parallel-connected drivers due to asymmetrical operation at turn-on and turn-off must be limited to the given value.
- 13) Maximum allowed rate of change of auxiliary emitter voltage of parallel connected drivers.
- 14) Dynamic voltages between auxiliary emitters of parallel connected drivers at turn-on and turn-off lead to equalizing currents over the X2 or X3 bus. The peak and RMS values of the resulting current must be limited to the given value.
- 15) Undervoltage monitoring of the secondary-side supply voltage (Viso to Vee and Vee to COM which correspond with the approximate turn-on and turn-off gate-emitter voltages). If the corresponding voltage drops below this limit on 1SP0335x2M1(C) (masters), all paralleled IGBTs (master and slaves) are switched off and a fault is transmitted to the status output. If the corresponding voltage drops below this limit on 1SP0335D2S1(C) (slaves), the corresponding IGBT is switched off. If the IGBT was turned on, a fault will be generated by the gate-monitoring function on the master which will turn off all paralleled IGBTs after the corresponding delay.
- The mean value V<sub>GE,mean</sub> of all gate voltages (master and all slaves) is filtered and compared to the given values at turn-on and turn-off. If the specified values are exceeded (V<sub>GE,mean</sub> < V<sub>GE,on,min</sub> at turn-on resp. V<sub>GE,mean</sub> > V<sub>GE,off,max</sub> at turn-off) after the given filter delay, the driver turns off all parallel-connected IGBTs and a fault is transmitted to the status output.
- 17) A dynamic Vce protection is implemented on the driver. The maximum allowed Vce voltage at turn-on is dynamically adjusted in order to better fit to the IGBT characteristics at turn-on. At the end of the turn-on process the given static value applies.
- 18) The resulting pulse width of the direct output of the gate drive unit for short-circuit type I (excluding the delay of the gate resistors) is the sum of the response time plus the delay to IGBT turn-off.
- 19) The turn-off event of the IGBT is delayed by the specified time after the response time.
- 20) Including the delay of the external fiber-optic links (cable length: 1m). Measured from the transition of the turn-on or turn-off command at the optical transmitter on the host controller side to the direct output of the gate drive unit (excluding the delay of the gate resistors).
- 21) Output rise and fall times are measured between 10% and 90% of the nominal output swing. The values are given for the driver side of the gate resistors with  $2\Omega/1$ uF load. The time constant of the output load in conjunction with the present gate resistors leads to an additional delay at their load side.
- 22) Delay of external fiber-optic links. Measured from the driver secondary side (ASIC output) to the optical receiver on the host controller (cable length: 1m).
- 23) Measured on the host side. The fault status on the secondary side is automatically reset after the specified time.
- 24) Including the delay of the external fiber-optic links (cable length: 1m). Measured from the transition of the turn-on or turn-off command at the optical transmitter on the host controller side to the transition of the acknowledge signal at the optical receiver on the host controller side.
- 25) The gate resistors can be leaded or surface mounted. Power Integrations reserves the right to determine which type will be used. Typically, higher quantities will be produced with SMD resistors and small quantities with leaded resistors.
- 26) The driver supply voltage VDC is split into two distinct voltages on the driver. The first one is the turn-on voltage which is regulated at about 15V. The difference between VDC and the turn-on voltage is the turn-off voltage which is not regulated and mainly dependent on the driver input voltage VDC.
- 27) The fault status is set as long as the gate monitoring fault is present. The given value applies if the driver goes from the "off state" to the "on state" and the gate-emitter voltage of one or more parallel connected drivers does not turn on. If the driver goes from the "on state" to the "off state" and the gate-emitter voltage of one or more parallel connected drivers does not turn off, the fault status is applied as long as the gate monitoring fault is present.
- 28) The storage temperature inside the original package (1) or in case the coating material of coated products may touch external parts (2) must be limited to the given value. Otherwise, it is limited to 90°C.
- 29) The component surface temperature, which may strongly vary depending on the operating condition, must be limited to the given value for coated driver versions to ensure long-term reliability of the coating material.



#### **Legal Disclaimer**

The statements, technical information and recommendations contained herein are believed to be accurate as of the date hereof. All parameters, numbers, values and other technical data included in the technical information were calculated and determined to our best knowledge in accordance with the relevant technical norms (if any). They may base on assumptions or operational conditions that do not necessarily apply in general. We exclude any representation or warranty, express or implied, in relation to the accuracy or completeness of the statements, technical information and recommendations contained herein. No responsibility is accepted for the accuracy or sufficiency of any of the statements, technical information, recommendations or opinions communicated and any liability for any direct, indirect or consequential loss or damage suffered by any person arising therefrom is expressly disclaimed.



### **Ordering Information**

Our international terms and conditions of sale apply.

Interface	Power Integrations Driver Type #	Related IGBT
Master, Fiber-Optic Interface 1)	1SP0335V2M1-CM900HG-90H	CM900HG-90H
Master, Fiber-Optic Interface 1), 3)	1SP0335V2M1C-CM900HG-90H	CM900HG-90H
Master, Fiber-Optic Interface 2)	1SP0335S2M1-CM900HG-90H	CM900HG-90H
Master, Fiber-Optic Interface <sup>2), 3)</sup>	1SP0335S2M1C-CM900HG-90H	CM900HG-90H
Slave, Electrical Interface	1SP0335D2S1-CM900HG-90H	CM900HG-90H
Slave, Electrical Interface 3)	1SP0335D2S1C-CM900HG-90H	CM900HG-90H

<sup>1)</sup> Fiber-optic interface with versatile link (HFBR-2522ETZ and HFBR-1522ETZ)

Product home page: <a href="https://www.power.com/gate-driver/go/1SP0335">www.power.com/gate-driver/go/1SP0335</a>

Refer to www.power.com/gate-driver/go/nomenclature for information on driver nomenclature

#### **Information about Other Products**

For other drivers, evaluation systems, product documentation and application support

Please click onto: <a href="https://www.power.com/gate-driver">www.power.com/gate-driver</a>

Fiber-optic interface with ST (HFBR-2412Z and HFBR-1412Z) See "Description & Application Manual for 1SP0335 SCALE-2 IGBT Drivers"

<sup>3)</sup> Conformal coated version



### **Power Integrations Sales Offices**

#### **WORLD HEADQUARTERS**

5245 Hellyer Avenue San Jose, CA 95138 USA Tel: +1-408-414-9200 Fax: +1-408-414-9765 Email: usasales@power.com

#### **AMERICAS WEST**

5245 Hellyer Avenue San Jose, CA 95138 USA Tel: +1-408-414-8778 Fax: +1-408-414-3760 Email: usasales@power.com

#### **GERMANY** (AC-DC/LED Sales)

Einsteinring 24 85609 Aschheim, Germany Tel: +49-89-5527-39100 Fax: +49-89-1228-5374 Email: eurosales@power.com

#### INDIA (Mumbai)

Unit: 106-107, Sagar Tech Plaza-B Sakinaka, Andheri Kurla Road Mumbai, Maharashtra 400072 India Tel 1: +91-22-4003-3700 Tel 2: +91-22-4003-3600 Email: indiasales@power.com

#### **JAPAN**

Kosei Dai-3 Bldg. 2-12-11, Shin-Yokohama, Kohoku-ku Yokohama-shi, Kanagawa Japan 222-0033 Tel: +81-45-471-1021

Fax: +81-45-471-3717 Email: japansales@power.com

#### **TAIWAN**

5F, No. 318, Nei Hu Rd., Sec. 1 Nei Hu Dist.

Taipei, 114 Taiwan Tel: +886-2-2659-4570 Fax: +886-2-2659-4550 Email: <u>taiwansales@power.com</u>

n Jose, CA 95138 USA Suite 225

### AMERICAS EAST

7360 McGinnis Ferry Road Suite 225 Suwannee, GA 30024 USA Tel: +1-678-957-0724 Fax: +1-678-957-0784 Email: usasales@power.com

#### CHINA (Shanghai)

Room 2410, Charity Plaza No. 88 North Caoxi Road Shanghai, 200030 China Tel: +86-21-6354-6323 Fax: +86-21-6354-6325 Email: chinasales@power.com

#### **GERMANY** (Gate Driver Sales)

HellwegForum 1 59469 Ense, Germany Tel: +49-2938-64-39990

Email: gate-drivers.sales@power.com

### INDIA (New Dehli)

#45, Top Floor Okhla Industrial Area, Phase - III New Dehli, 110020 India Tel 1: +91-11-4055-2351 Tel 2: +91-11-4055-2353 Email: indiasales@power.com

#### **KOREA**

RM602, 6FL, 22 Teheran-ro 87-gil, Gangnam-gu Seoul, 06164 Korea Tel: +82-2-2016-6610 Fax: +82-2-2016-6630 Email: koreasales@power.com

#### **UNITED KINGDOM**

Bulding 5, Suite 21
The Westbrook Centre
Milton Road
Cambridge, CB4 1YG United Kingdom

Tel: +44-7823-557-484 Email: <u>eurosales@power.com</u>

#### **AMERICAS CENTRAL**

333 Sheridan Road Winnetka, IL 60093 USA Tel: +1-847-721-6293 Email: usasales@power.com

#### CHINA (Shenzhen)

17/F, Hivac Building, No 2 Keji South 8th Road, Nanshan District Shenzhen, 518057 China

Tel: +86-755-8672-8689 Fax: +86-755-8672-8690 Email: <u>chinasales@power.com</u>

## **INDIA** (Bangalore) #1, 14th Main Road

Vasanthangar Bangalore, 560052 India Tel 1: +91-80-4113-8020 Tel 2: +91-80-4113-8028 Fax: +91-80-4113-8023

Email: indiasales@power.com

Email: eurosales@power.com

#### **ITALY**

Via Milanese 20 20099 Sesto San Giovanni (MI), Italy Tel: +39-02-4550-8708

#### SINGAPORE

51 Newton Road #19-01/05 Goldhill Plaza Singapore, 308900 Tel 1: +65-6358-2160 Tel 2: +65-6358-4480 Fax: +65-6358-2015

Email: singaporesales@power.com

# **Mouser Electronics**

**Authorized Distributor** 

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

**Power Integrations:** 

1SP0335S2M1-CM900HG-90H



Компания «ЭлектроПласт» предлагает заключение долгосрочных отношений при поставках импортных электронных компонентов на взаимовыгодных условиях!

#### Наши преимущества:

- Оперативные поставки широкого спектра электронных компонентов отечественного и импортного производства напрямую от производителей и с крупнейших мировых складов:
- Поставка более 17-ти миллионов наименований электронных компонентов;
- Поставка сложных, дефицитных, либо снятых с производства позиций;
- Оперативные сроки поставки под заказ (от 5 рабочих дней);
- Экспресс доставка в любую точку России;
- Техническая поддержка проекта, помощь в подборе аналогов, поставка прототипов;
- Система менеджмента качества сертифицирована по Международному стандарту ISO 9001:
- Лицензия ФСБ на осуществление работ с использованием сведений, составляющих государственную тайну;
- Поставка специализированных компонентов (Xilinx, Altera, Analog Devices, Intersil, Interpoint, Microsemi, Aeroflex, Peregrine, Syfer, Eurofarad, Texas Instrument, Miteq, Cobham, E2V, MA-COM, Hittite, Mini-Circuits, General Dynamics и др.);

Помимо этого, одним из направлений компании «ЭлектроПласт» является направление «Источники питания». Мы предлагаем Вам помощь Конструкторского отдела:

- Подбор оптимального решения, техническое обоснование при выборе компонента;
- Подбор аналогов;
- Консультации по применению компонента;
- Поставка образцов и прототипов;
- Техническая поддержка проекта;
- Защита от снятия компонента с производства.



#### Как с нами связаться

**Телефон:** 8 (812) 309 58 32 (многоканальный)

Факс: 8 (812) 320-02-42

Электронная почта: org@eplast1.ru

Адрес: 198099, г. Санкт-Петербург, ул. Калинина,

дом 2, корпус 4, литера А.