OMRON

DC Power Relays (60-A, 100-A Models) G9EA-1


DC Power Relays Capable of Interrupting High-voltage, High-current Loads

- A compact relay (73 x 36 x 67.2 mm (L x W x H)) capable of switching 400-V 60-A DC loads. (Capable of interrupting 600 A at 300 VDC max.)
- The switching section and driving section are gas-injected and hermetically sealed, allowing these compact relays to interrupt high-capacity loads. The sealed construction also requires no arc space, saves space, and helps ensure safe applications.
- Downsizing and optimum design allow no restrictions on the mounting direction.
- Terminal Cover and DIN Track Adapters are also available for industrial applications.
- UL/CSA standard UL508 approved.

Note: Refer to *Precautions* on page 22.

Model Number Structure

Model Number Legend



- 1. Number of Poles
- 1: 1 pole 2. Contact Form
- Blank: SPST-NO
 3. Coil Terminals
 - B: M3.5 screw terminals Blank: Lead wire output
- 4. Special Functions
 - CA: High-current conduction (100 A)

Ordering Information

■ List of Models

Models	Terminals		Contact form	Rated coil voltage	Model
	Coil terminals	Contact terminals			
	Screw terminals (See note 2.)		SPST-NO		G9EA-1-B
duction models	Lead wires	(See note 1.)		48 VDC 60 VDC	G9EA-1
High-current conduc- tion models	Screw terminals (See note 2.)				G9EA-1-B-CA
	Lead wires				G9EA-1-CA

Note: 1. Two M5 screws are provided for the contact terminal connection.

2. Two M3.5 screws are provided for the coil terminal connection.



Specifications

Ratings

Coil

Rated voltage	Rated current	Coil resistance	Must-operate voltage	Must-release voltage	Maximum voltage (See note 3.)	Power consumption
12 VDC	417 mA	28.8 Ω	75% max. of rated	8% min. of rated		Approx. 5 W
24 VDC	208 mA	115.2 Ω	voltage	voltage	age (at 23°C within	
48 VDC	102 mA	469.3 Ω	-		10 minutes)	
60 VDC	86.2 mA	695.7 Ω	-			Approx. 5.2 W
100 VDC	53.6 mA	1,864 Ω				Approx. 5.4 W

Note: 1. The figures for the rated current and coil resistance are for a coil temperature of 23°C and have a tolerance of ±10%.

2. The figures for the operating characteristics are for a coil temperature of 23°C.

3. The figure for the maximum voltage is the maximum voltage that can be applied to the relay coil.

Contacts

Item	Resistive load			
	G9EA-1(-B)	G9EA-1(-B)-CA		
Rated load	60 A at 400 VDC, 100 A at 120 VDC	30 A at 400 VDC		
Rated carry current	60 A	100 A		
Maximum switching voltage	400 V	400 V		
Maximum switching current	100 A	30 A		

■ Characteristics

Item		G9EA-1(-B)	G9EA-1(-B)-CA	
Contact resistance (See note 2.)		30 mΩ max. (0.6 mΩ typical)	10 m Ω max. (0.3 m Ω typical)	
· · · · · · · · · · · · · · · · · · ·		0.1 V max. (for a carry current of 60 A)	0.1 V max. (for a carry current of 100 A)	
Operate time		50 ms max.		
Release time		30 ms max.		
Insulation resistance	Between coil and contacts	1,000 MΩ min.		
(See note 3.)	Between contacts of the same polarity	1,000 MΩ min.		
Dielectric strength	Between coil and contacts	2,500 VAC, 1 min		
	Between contacts of the same polarity	2,500 VAC, 1 min		
Impulse withstand voltage (See note 4.)		4,500 V		
Vibration resistance	Destruction	10 to 55 to 10 Hz, 0.75-mm single amplitude (Acceleration: 2.94 to 88.9 m/s ²		
	Malfunction	10 to 55 to 10 Hz, 0.75-mm single amplitude (Acceleration: 2.94 to 88.9 m/s ²		
Shock resistance Destruction		490 m/s ²		
	Malfunction	196 m/s ²		
Mechanical endurance (See note 5.)		200,000 ops. min.		
Electrical endurance (S	ee note 6.)	120 VDC, 100 A, 3,000 ops. min.	400 VDC, 30 A, 1,000 ops. min.	
		400 VDC, 60 A, 3,000 ops. min.	120 VDC, 30 A, 2,500 ops. min.	
		400 VDC, 30 A, 30,000 ops. min.		
Short-time carry curre	nt	100 A (10 min)	150 A (10 min)	
Maximum interruption	current	600 A at 300 VDC (5 times)		
Overload interruption		180 A at 400 VDC (100 times min.)	100 A at 120 VDC (150 times min.)	
Reverse polarity interruption		-60 A at 200 VDC (1,000 times min.)		
Ambient operating temperature		-40 to 70°C (with no icing or condensation)		
Ambient operating humidity		5% to 85%		
Weight		Approx. 310 g		

Note: 1. The above values are initial values at an ambient temperature of 23°C unless otherwise specified.

2. The contact resistance was measured with 1 A at 5 VDC using the voltage drop method.


3. The insulation resistance was measured with a 500-VDC megohmmeter.


4. The impulse withstand voltage was measured with a JEC-212 (1981) standard impulse voltage waveform ($1.2 \times 50 \mu$ s).

5. The mechanical endurance was measured at a switching frequency of 3,600 operations/hr.

6. The electrical endurance was measured at a switching frequency of 60 operations/hr.

■ G9EA-1(-B) Switching/Current Conduction Models







OMRON



Must-operate Voltage and Must-release Voltage Distributions 30 Must-operate voltage Sample: G9EA-1 Number: 35 Must-release voltage 25





Vibration Resistance



Characteristics were measured after applying vibration at a frequency of 10 to 55 Hz (single amplitude of 0.75 mm) to the test piece (not energized) for 2 hours each in 3 directions. The percentage rate of change is the average value for all of the samples


Time Characteristic Distributions






The value at which malfunction occurred was measured after applying shock to the test piece 3 times each in 6 directions along 3 axes.

Vibration Malfunction



Shock Resistance




Characteristics were measured after applying a shock of 490 m²/s to the test piece 3 times each in 6 directions along 3 axes. The percentage rate of change is the average value for all of the samples.

Dimensions

Note: All units are in millimeters unless otherwise indicated.

Models with Screw Terminals


G9EA-1-B(-CA)




OMRON

■ Options Terminal Cover

P9EA-C





13.2* 21

-17


-| |+-17 ⊿9 ---- Note: Be sure to remove the cutouts for wiring that are located in the wiring outlet direction before installing the Terminal Cover.

Dimension (mm)	Tolerance (mm)
10 or lower	±0.3
10 to 50	±0.5
50 or higher	±1

* Dimensions of cutouts for wiring.

DIN Track Adapter





Dimension (mm)	Tolerance (mm)
10 or lower	±0.3
10 to 50	±0.5
50 or higher	±1



Precautions

Take measures to prevent contact with charged parts when using the Relay for high voltages.



Precautions for Correct Use

Refer to the relevant catalog for common precautions.

- 1. Be sure to tighten all screws to the appropriate torque given below. Loose screws may result in burning due to abnormal heat generation during energization.
 - M8 screws: 8.82 to 9.80 N·m
 - M6 screws: 3.92 to 4.90 N·m
 - M5 screws: 1.57 to 2.35 N·m
 - M4 screws: 0.98 to 1.37 N·m
 - M3.5 screws: 0.75 to 1.18 N·m
- The G9EA and G9EC Relays' contacts have polarity. Be sure to perform connections with the correct polarity. If the contacts are connected with the reverse polarity, the switching characteristics specified in this document cannot be assured.
- Do not drop or disassemble this Relay. Not only may the Relay fail to meet the performance specifications, it may also result in damage, electric shock, or burning.
- 4. Do not use these Relays in strong magnetic fields of 800 A/m or higher (e.g., near transformers or magnets). The arc discharge that occurs during switching may be bent by the magnetic field, resulting in flashover or insulation faults.
- 5. This Relay is a device for switching high DC voltages. If it is used for voltages exceeding the specified range, it may not be possible to interrupt the load and burning may result. In order to prevent fire spreading, use a configuration in which the current load can be interrupted in the event of emergencies.

In order to ensure safety of the system, replace the Relay on a regular basis.

- 6. If the Relay is used for no-load switching, the contact resistance may increase and so confirm correct operation under the actual operating conditions.
- 7. These Relays contain pressurized gas. Even in applications with low switching frequencies, the ambient temperature and heat caused by arc discharge in the contacts may allow permeation of the sealed gas, resulting in arc interruption failure. In order to ensure safety of the system, replace Relays on a regu-

In order to ensure satety of the system, replace Relays on a regular basis.

- Do not use or store the Relay in a vacuum. Doing so will accelerate deterioration of the sealing.
- 9. With this Relay, if the rated voltage (or current) is continuously applied to the coil and contacts, and then turned OFF and immediately ON again, the coil temperature, and consequently the coil resistance, will be higher than usual. This means that the must operate voltage will also be higher than usual, exceeding the rated value ("hot start"). In this case, take the appropriate countermeasures, such as reducing the load current or restricting the energizing time or ambient operating temperature.
- **10.** The ripple percentage for DC relays can cause fluctuations in the must-operate voltage or humming. For this reason, reduce the ripple percentage in full-wave rectified power supply circuits by adding a smoothing capacitor. Ensure that the ripple percentage is less than 5%.
- **11.**Ensure that a voltage exceeding the specified maximum voltage is not continuously applied to the coil. Abnormal heating in the coil may shorten the lifetime of the insulation coating.
- 12.Do not use the Relay at a switching voltage or current greater than the specified maximum values. Doing so may result in arc discharge interruption failure or burning due to abnormal heating in the contacts.

22

- **13.**The contact ratings are for resistive loads. The electrical endurance with inductive loads is inferior to that of resistive loads. Confirm correct operation under the actual operating conditions.
- 14.Do not use the Relay in locations where water, solvents, chemicals, or oil may come in contact with the case or terminals. Doing so may result in deterioration of the case resin or abnormal heating due to corrosion or contamination of the terminals. Also, if electrolyte adheres to the output terminals, electrolysis may occur between the output terminals, resulting in corrosion of the terminals or wiring disconnections.
- 15.Be sure to turn OFF the power and confirm that there is no residual voltage before replacing the Relay or performing wiring.
- **16.**The distance between crimp terminals or other conductive parts will be reduced and insulation properties will be lowered if wires are laid in the same direction from the contact terminals. Use insulating coverings, do not wire in the same direction, and take other measures as required to maintain insulation properties.
- 17.Use either a varistor, or a diode plus Zener diode as a protective circuit against reverse surge in the relay coil. Using a diode alone will reduce the switching characteristics.
- 18.Be sure to use the screws provided with the product for wiring coil terminals and contact terminals. The specified tightening torque cannot be achieved with different screws and may result in abnormal heat generation when energized.

Recommended Wire Size

Model	Size
G9EA-1(-B)	14 to 22 mm ²
G9EA-1(-B)-CA	22 to 38 mm ²
G9EC-1(-B)	38 to 60 mm ²
G9EB-1-B	2 to 5.5 mm ²

Note: Use flexible leads.



Компания «ЭлектроПласт» предлагает заключение долгосрочных отношений при поставках импортных электронных компонентов на взаимовыгодных условиях!

Наши преимущества:

- Оперативные поставки широкого спектра электронных компонентов отечественного и импортного производства напрямую от производителей и с крупнейших мировых складов;
- Поставка более 17-ти миллионов наименований электронных компонентов;
- Поставка сложных, дефицитных, либо снятых с производства позиций;
- Оперативные сроки поставки под заказ (от 5 рабочих дней);
- Экспресс доставка в любую точку России;
- Техническая поддержка проекта, помощь в подборе аналогов, поставка прототипов;
- Система менеджмента качества сертифицирована по Международному стандарту ISO 9001;
- Лицензия ФСБ на осуществление работ с использованием сведений, составляющих государственную тайну;
- Поставка специализированных компонентов (Xilinx, Altera, Analog Devices, Intersil, Interpoint, Microsemi, Aeroflex, Peregrine, Syfer, Eurofarad, Texas Instrument, Miteq, Cobham, E2V, MA-COM, Hittite, Mini-Circuits, General Dynamics и др.);

Помимо этого, одним из направлений компании «ЭлектроПласт» является направление «Источники питания». Мы предлагаем Вам помощь Конструкторского отдела:

- Подбор оптимального решения, техническое обоснование при выборе компонента;
- Подбор аналогов;
- Консультации по применению компонента;
- Поставка образцов и прототипов;
- Техническая поддержка проекта;
- Защита от снятия компонента с производства.



Как с нами связаться

Телефон: 8 (812) 309 58 32 (многоканальный) **Факс:** 8 (812) 320-02-42 **Электронная почта:** <u>org@eplast1.ru</u> **Адрес:** 198099, г. Санкт-Петербург, ул. Калинина, дом 2, корпус 4, литера А.