

MACX MCR-EX-SL-NAM-2RO(-SP)



Intrinsically safe NAMUR isolating amplifier with two relay outputs

INTERFACE

Data sheet
103465_en_00

© PHOENIX CONTACT - 08/2008

1 Description

The NAMUR **MACX MCR-EX-SL-NAM-2RO(-SP)** isolating amplifier has been designed for intrinsically safe operation of the proximity sensors (as per EN 60947-5-6 (NAMUR)) and the floating and resistance circuit mechanical contacts installed in the Ex area.

The input circuit is monitored for line faults (breakage and short circuit (LFD)) (can be switched on/off). Errors are indicated via a red flashing LED (as per NE 44) and the relevant output relay is de-energized. Error messages are also transmitted to the power and error evaluation module via the DIN rail connector.

The output side has two N/O contact relays. Both can be operated as signal outputs. Output 2 can also be used as an error message output (can be adjusted via the DIP switch). The switch can be used to set the direction (open or closed circuit current behavior). The relay status is indicated via a yellow LED.

The modules can be installed in zone 2 with the "n" (EN 60079-15) protection type.

1.1 Properties

- Input for NAMUR proximity sensor or switch, [Ex ia] IIC
- Two relay signal outputs (N/O contact); output 2 can be used as an error message output
- Line fault detection (LFD)
- Option of phase reversal
- 3-way electrical isolation
- SIL 2 according to EN 61508
- Installation in Zone 2 permissible
- Power supply and error message possible via the DIN rail connector
- With screw (MACX MCR-EX-SL-NAM-2RO) or spring-cage connection (MACX MCR-EX-SL-NAM-2RO-SP)



WARNING: Explosion hazard

The module is an associated item of electrical equipment for intrinsically safe circuits. It is designed for use in zone 2, if specific conditions are observed.

When installing and operating the device, the applicable safety directives (including national safety directives), accident prevention regulations, as well as general technical regulations, must be observed.



WARNING: Explosion hazard

Be sure to observe the safety regulations and installation notes on page 5.



Make sure you always use the latest documentation.
It can be downloaded at www.download.phoenixcontact.com.
A conversion table is available on the Internet at
www.download.phoenixcontact.com/general/7000_en_00.pdf.



This data sheet is valid for all products listed on the following page:

Table of contents

| | | |
|---|--|----|
| 1 | Description..... | 1 |
| 2 | Ordering data..... | 2 |
| 3 | Technical data | 2 |
| 4 | Safety regulations and installation notes..... | 5 |
| 5 | Installation | 6 |
| 6 | Configuration | 8 |
| 7 | Comparison of safety data | 10 |
| 8 | Switch on | 10 |
| 9 | Safety-related applications (SIL 2)..... | 11 |

2 Ordering data

NAMUR isolating amplifiers

| Description | Type | Order No. | Pcs./Pkt. |
|---|---------------------------|-----------|-----------|
| Intrinsically safe NAMUR isolating amplifier, with two relay outputs and screw connection | MACX MCR-EX-SL-NAM-2RO | 2865450 | 1 |
| Intrinsically safe NAMUR isolating amplifier, with two relay outputs and spring-cage connection | MACX MCR-EX-SL-NAM-2RO-SP | 2924061 | 1 |

Accessories

| Description | Type | Order No. | Pcs./Pkt. |
|--|--------------------------------|-----------|-----------|
| DIN rail connector (T-BUS), 5-pos., for bridging the supply voltage, can be snapped onto NS 35/... DIN rails according to EN 60715 | ME 6.2 TBUS-2 1.5/5-ST-3.81 GN | 2869728 | 10 |
| Power and error evaluation module, including the relevant DIN rail connector ME 17.5 TBUS 1.5/5-ST-3.81 GN | | | |
| Screw connection | MACX MCR-PTB | 2865625 | 1 |
| Spring-cage connection | MACX MCR-PTB-SP | 2924184 | 1 |



For additional accessories, please refer to the "INTERFACE" catalog from Phoenix Contact.

3 Technical data

| Input | |
|-------------------------|---|
| Input | Intrinsically safe, designed for protection type Ex-i [Ex ia] IIC |
| Available input sources | <ul style="list-style-type: none"> - NAMUR proximity switches according to EN 60947-5-6 or - Switch contacts with open circuit - (not for safety-related applications, SIL 2) or - Switch contacts with resistance circuit |
| Switching hysteresis | < 0.2 mA |

Control circuit

| | |
|--|---|
| Non-load voltage | 8 V DC \pm 10% |
| Switching points according to EN 60947-5-6 | I < 1.2 mA (blocking) I > 2.1 mA (conductive) |
| Line fault detection | Break 0.05 mA < I _N < 0.35 mA Short circuit 100 Ω < R _{sensor} < 360 Ω Activated/deactivated via DIP switch |

Switching output

| | |
|---------------------------|--|
| Switching output | Relay, 2 x N/O contacts |
| Switching behavior | Can be inverted using DIP switch |
| Switching frequency | 20 Hz (without load) |
| Maximum switching voltage | 250 V AC (2 A) 120 V DC (0.2 A) 30 V (2 A) |
| Maximum switching power | 500 VA |
| Contact material | AgSnO ₂ , gold-plated |
| Service life | |
| Mechanical | 10 ⁷ cycles |
| Recommended minimum load | 5 V/10 mA |

General data

| | |
|---|--|
| Supply voltage range | 19.2 V DC ... 30 V DC |
| Current consumption, maximum | 30 mA (24 V DC) |
| Power dissipation | < 950 mW |
| Electrical isolation | |
| Input/output | 375 V (peak value according to EN 60079-11) |
| Input/power supply | 375 V (peak value according to EN 60079-11) |
| Input/power supply, DIN rail connector | 300 V _{rms} (rated insulation voltage, surge voltage category II, pollution degree 2, safe isolation as per EN 61010, EN 50178) 1.5 kV AC (50 Hz, 1 min., test voltage) |
| Output 1/output 2/input, power supply, DIN rail connector | 300 V _{rms} (rated insulation voltage, surge voltage category III; pollution degree 2, safe isolation as per EN 61010, EN 50178) 2.5 kV AC (50 Hz, 1 min., test voltage) |
| Ambient temperature | |
| Operation | -20°C ... +60°C (any mounting position) |
| Storage/transport | -40°C ... +80°C |
| Permissible humidity (operation) | 10% ... 95% (no condensation) |
| Status indicator | Green LED (PWR, supply voltage) Red LED (LE, line errors) Yellow LED (OUT, switching state) |
| Housing material | PBT |
| Color | Green |
| Degree of protection | IP20 |
| Width x length x height | 12.5 mm x 114.5 mm x 104 mm (with connection terminal block) |
| Inflammability class according to UL 94 | V0 |
| Design | Terminal block housing for mounting on DIN rails |

Conformance

| | |
|---------------------------|--|
| EMC directive 2004/108/EC | EN 61000-6-2, EN 61000-6-4, EN 61326-1 |
| Ex directive (ATEX) | EN 60079-0, EN 60079-11, EN 60079-15 |

Safety data according to ATEX for intrinsically safe circuits

| | | | | | | | | |
|--------------------------------------|---------------------|--------|-------------|-------------|-------------|-------------|-------------|------------|
| Maximum voltage U_o | 9.6 V | | | | | | | |
| Maximum current I_o | 10 mA | | | | | | | |
| Maximum power P_o | 25 mW | | | | | | | |
| Maximum inner inductance L_i | Negligible | | | | | | | |
| Maximum inner capacitance C_i | 11 nF | | | | | | | |
| Gas group | IIC | | | | IIB | | | |
| Maximum external inductance L_o | 100 mH | 5 mH | 1 mH | 10 μ H | 100 mH | 5 mH | 1 mH | 10 μ H |
| Maximum external capacitance C_o | 510 nF | 840 nF | 1.2 μ F | 3.6 μ F | 2.7 μ F | 4.4 μ F | 6.3 μ F | 26 μ F |
| Safety-related maximum voltage U_m | 253 V AC (125 V DC) | | | | | | | |

Certificates

| | |
|-------------------------|--|
| ATEX | Ex II (1) GD [Ex ia] IIC, IIB IBExU 07 ATEX 1069 Ex II (3) G Ex nAC II T4 X |
| IECEX approval | [Ex ia] IIC; [Ex ia D]; Ex nAC IIC T4 IECEX IBE 08.0001X |
| UL USA/Canada | Applied for |
| Functional safety (SIL) | SIL 2 according to EN 61508 |

Connection data MACX MCR-EX-SL-NAM-2RO

| | |
|-----------------------------|--|
| Conductor cross-section | |
| Solid (minimum/maximum) | 0.2 mm ² /2.5 mm ² |
| Stranded (minimum/maximum) | 0.2 mm ² /2.5 mm ² |
| AWG/kcmil (minimum/maximum) | 24/14 |
| Stripping length | 7 mm |
| Connection method | Pluggable screw connection |
| Tightening torque | 0.5 Nm, minimum/0.6 Nm, maximum |

Connection data MACX MCR-EX-SL-NAM-2RO-SP

| | |
|-----------------------------|--|
| Conductor cross-section | |
| Solid (minimum/maximum) | 0.2 mm ² /1.5 mm ² |
| Stranded (minimum/maximum) | 0.2 mm ² /1.5 mm ² |
| AWG/kcmil (minimum/maximum) | 24/16 |
| Stripping length | 8 mm |
| Connection method | Spring-cage connection |

4 Safety regulations and installation notes

4.1 Installation and operation

Follow the installation instructions.



NOTE: Installation, operation, and maintenance may only be carried out by qualified specialist personnel.

When installing and operating the device, the applicable safety directives (including national safety directives), accident prevention regulations, as well as general technical regulations must be observed.



NOTE: The circuits inside the device must not be accessed.

Do not repair the device yourself, but replace it with an equivalent device. Repairs may only be carried out by the manufacturer.



NOTE: The device is designed to meet IP20 protection when:

- It is installed outside potentially explosive areas.
- The environment is clean and dry.

Install the device in a suitable housing with a suitable degree of protection in accordance with IEC 60529 in order to protect it from mechanical and electrical damage.

For the safety data, please refer to the operating instructions and certificates (EC type-examination, other approvals, if necessary).



NOTE: The load connected to the relay outputs should be limited to the values listed in the technical data.

4.2 Safety regulations for installation in potentially explosive areas

Regulations for intrinsically safe circuits



WARNING: Explosion hazard
When carrying out **measurements** on the intrinsically safe side, be sure to observe the relevant regulations regarding the connection of intrinsically safe equipment.
Only use devices approved for use in intrinsically safe circuits.



WARNING: Explosion hazard
If the device has been used in **non-intrinsically safe circuits**, it must **not** be used again in intrinsically safe circuits.
Clearly label the module as being non-intrinsically safe.

Installation in Zone 2



WARNING: Explosion hazard
The device is associated equipment of the "Ex-i" protection type and suitable for installation in Zone 2.

Observe the specified conditions for use in potentially explosive areas.



WARNING: Explosion hazard
Install the device in suitable **housing with a minimum of IP54 degree of protection**.
Observe the requirements of IEC 60079-14/EN 60079-14, e.g., steel housing with a wall thickness of 3 mm.



WARNING: Explosion hazard
Disconnect the block **power supply before**:

- Snapping it on or disconnecting it.
- Connecting or disconnecting cables of non-intrinsically safe circuits.



WARNING: Explosion hazard
Only use category 3G modules (ATEX 94/9/EC).

Installation in areas with a danger of dust explosions



WARNING: Explosion hazard
The device is **not** designed for installation in areas with a danger of dust explosions.

Connection to the **intrinsically safe circuit in areas with a danger of dust explosions** (zones 20, 21, and 22) is **only** permitted if the equipment connected to this circuit is approved for this zone (e.g., category 1D, 2D or 3D).

4.3 Use in safety-related applications (SIL 2)

When using the MACX MCR-EX-SL-NAM-2RO(-SP) in safety-related applications, observe the instructions in Section 9, as the requirements differ for safety-related functions.

5 Installation



NOTE: Electrostatic discharge

The device contains components that can be damaged or destroyed by electrostatic discharge. When handling the device, observe the necessary safety precautions against electrostatic discharge (ESD) according to EN 61340-5-1 and EN 61340-5-2.

5.1 Basic circuit diagram




Figure 1 Basic circuit diagram with connection terminal blocks

5.2 Design




Figure 2 Design

- 1 COMBICON plug connectors
- 2 PWR LED (green), for indicating the power supply
- 3 LED LF1/LF2 (red), for indicating line faults on the sensor cable
- 4 LED OUT1 (yellow), for indicating switching state of relay output 1
- 5 LED OUT2 (yellow), for indicating switching state of relay output 2
- 6 Switch DIP1 ... DIP4
- 7 Metal lock for fixing on the DIN rail
- 8 Connection option for DIN rail connector

5.3 Dimensions




Figure 3 Dimensions (in mm)

5.4 Mounting



WARNING: Explosion hazard

If the module has been used in non-intrinsically safe circuits, it must not be used again in intrinsically safe circuits. Clearly label the module as being non-intrinsically safe.




Figure 4 Assembly and removal

- Mount the module on a 35 mm DIN rail according to EN 60715.
- When using the DIN rail connector, first place it into the DIN rail (see A – C, Figure 4). It is used to bridge the voltage supply and for error messages.
Please also ensure you observe the direction of the module and DIN rail connector when snapping into position:
Snap-on foot below (2) and connector left (1).
- Install the module in suitable housing to meet the requirements for the protection class.
- Before startup, check that the NAMUR isolating amplifier is operating and wired correctly, especially with regard to the wiring and labeling of the intrinsically safe circuits.

5.5 Connecting the cables

- Pluggable screw terminal blocks (on MACX MCR-EX-SL-NAM-2RO); litz wires provided with ferrules.
- Pluggable spring-cage terminal blocks (on MACX MCR-EX-SL-NAM-2RO-SP); litz wires provided with ferrules.
- Lay intrinsically safe and non-intrinsically safe cables separately.
- Permissible cable cross-section: 0.2 mm² to 2.5 mm².

– Screw connection:

- Insert the wire into the corresponding connection terminal block.
- Use a screwdriver to tighten the screw in the opening above the connection terminal block.

– Spring-cage connection:

- Insert a screwdriver in the opening above the connection terminal block.
- Insert the wire into the corresponding connection terminal block.

5.6 Voltage supply



NOTE: Never connect the supply voltage directly to the DIN rail connector. It is not permitted to draw power from the DIN rail connector or from individual MACX-MCR-EX modules.

The modules can be powered via the connection terminal blocks 1.1 (+24 V) and 1.2 (GND) or via the DIN rail connector (ME 6.2 TBUS-... , order no. 2869728).

Depending on the number of modules to be powered, the voltage is either fed via the MACX MCR-EX-SL-NAM-2RO(-SP) or the power and error evaluation module MACX MCR-PTB(-SP) on the DIN rail connector.

Supply via the module

Where the total current consumption of the aligned modules does not exceed 400 mA, the power can be supplied directly at the connection terminal blocks of the module. A 400 mA fuse should be connected upstream.

The voltage supply is provided at the connection terminal blocks 1.1 (+24 V) and 1.2 (GND).

Infeed via the power and error evaluation module MACX MCR-PTB(-SP)

The supply voltage is fed in via the module MACX MCR-PTB(-SP) to the DIN rail connectors. The supply voltage can be provided as either simple or redundant.

The module MACX MCR-PTB(-SP) has integrated error evaluation. An auxiliary supply failure or fuse error is registered to a relay contact and displayed via a flashing LED.

Collection line faults of all modules connected via the DIN rail connectors are also signaled.

6 Configuration

In the default state upon delivery, all DIP switches are set to the position "I".



- DIP1 = I Normal phase
- DIP1 = II Inverted phase
- DIP2 = I Line fault detection disabled*
- DIP2 = II Line fault detection enabled
- PWR = Supply voltage
- OUT1 = Switching state of relay output 1
- OUT2 = Switching state of relay output 2
- LF = Line fault on the sensor cable

* (Not permitted for safety-related applications, SIL 2)

6.1 Line fault detection (switch DIP2)



WARNING: For safety-related applications, **only** the switch position "DIP2 = II" is **permitted**.

Line fault detection is enabled or disabled using switch DIP2. When line fault detection is enabled, the relay drops out in the event of a cable interrupt or short circuit to the sensor so that the output is set to the safe, non-conductive state. The red LED (LF) flashes.

Operating range for the

- Cable break alarm $50 \mu\text{A} > I > 350 \mu\text{A}$
- Short circuit alarm $100 \Omega > R > 360 \Omega$

If the module is connected to a power module MACX MCR-PTB(-SP) via a DIN rail connector, a group error message is also sent to the higher-level evaluation unit via floating relay output.



NOTE: For **switch contacts with open circuit** (Figure 5), line fault detection (DIP2 = I) must be disabled or the corresponding resistance circuit must be provided directly at the switch contact (Figure 6, e. g. UKK 5-2R/NAMUR (Order No. 2941662) with D-UKK 3/5 (Order No. 2770024)).




Figure 5 Switch contact with open circuit

(Not permitted for safety-related applications, SIL 2)




Figure 6 Switch contact with resistance circuit

6.2 Phase reversal (switch DIP1)

The phase reversal function is enabled or disabled using switch DIP1.

| Output relay | Normal phase (I) | Inverted phase (II) |
|-------------------------|----------------------|----------------------|
| Switched if | $I > 2.1 \text{ mA}$ | $I < 1.2 \text{ mA}$ |
| In normal position when | $I < 1.2 \text{ mA}$ | $I > 2.1 \text{ mA}$ |

6.3 Output OUT2 (switch DIP3/DIP4)



- | DIP3 | DIP4 | Operating mode OUT2 |
|------|------|---------------------|
| X | = II | Signal duplicator |
| = II | = I | Error indicator |
| = II | = II | Disabled |

6.4 Truth table



WARNING: For safety-related applications, **only** the switch position "DIP2 = II" is **permitted**.



WARNING: Only switch contacts with resistance circuit are **permitted** at the input for safety-related applications (see Figure 6).

| | Sensor in Input | | Input circuit | DIP | | Relay contact output (N/O contact) | | | | LED OUT Yellow | LF LED Red |
|--|-----------------|------------|-------------------|-------|----|------------------------------------|--------|-----------------|--------------|-------------------|---------------|
| | Switch | NAMUR | | State | 1 | 2 | OUT1 | OUT2 | | | |
| | | | Signal duplicator | | | | | Error indicator | Disconnected | | |
| | Open | Blocking | OK | I | I | Open | Open | Open | Open | | |
| | Closed | Conductive | OK | I | I | Closed | Closed | Open | Open | X | |
| | Open | Blocking | OK | II | I | Closed | Closed | Open | Open | X | |
| | Closed | Conductive | OK | II | I | Open | Open | Open | Open | | |
| | | Blocking | OK | I | II | Open | Open | Open | Open | | |
| | | Conductive | OK | I | II | Closed | Closed | Open | Open | X | |
| | | Any | Open circuit | I | II | Open | Open | Closed | Open | | X |
| | | Any | Short circuit | I | II | Open | Open | Closed | Open | | X |
| | | Blocking | OK | II | II | Closed | Closed | Open | Open | X | |
| | | Conductive | OK | II | II | Open | Open | Open | Open | | |
| | | Any | Open circuit | II | II | Open | Open | Closed | Open | | X |
| | | Any | Short circuit | II | II | Open | Open | Closed | Open | | X |

DIP2 = I Line fault detection disabled
(not permitted for safety-related applications, SIL 2)

DIP2 = II Line fault detection enabled

DIP1 = I Normal phase

DIP1 = II Inverted phase

DIP4 = II Signal duplicator

DIP 3 = II + DIP4 = I Error indicator

DIP 3 = II + DIP4 = II Disabled

PWR LED = Supply voltage

LED OUT1 = Switching state of relay output 1

LED OUT2 = Switching state of relay output 2

LF LED = Line fault on the sensor cable

7 Comparison of safety data



WARNING: Explosion hazard

Compare the safety data before connecting a module located in the intrinsically safe area to the MACX MCR-EX-SL-NAM-2RO(-SP).

Safety data for

Field devices: U_i, I_i, P_i, L_i, C_i

Isolation amplifier: U_o, I_o, P_o, L_o, C_o

For the values for U_o, I_o, P_o, L_o and C_o , please refer to "Safety data according to ATEX for intrinsically safe circuits" on page 4.

Requirements for intrinsic safety (simple circuits):

$$U_i \geq U_o$$

$$I_i \geq I_o$$

$$P_i \geq P_o$$

$$L_i + L_c \leq L_o$$

$$C_i + C_c \leq C_o$$

(L_c and C_c depend on the cables/lines used).

8 Switch on



NOTE: Around 5 seconds after switching on the main power, the module is ready for use.

It depends on the operating conditions as to whether the module reaches its specified accuracy immediately or whether there is a warm-up period.

The greatest possible accuracy is achieved when the unit has been running for around 2 hours.

9 Safety-related applications (SIL 2)

9.1 Wiring

Input

Permitted for safety-related applications:

- NAMUR sensor (according to EN 60947-5-6)
- Switch contact with resistance circuit (1 kΩ serial and 10 kΩ parallel (tolerance ±10%))
(Note: The resistance circuit regulates the behavior of a NAMUR sensor)



WARNING: Switch contacts without resistance circuit are **not permitted** for safety-related applications.

Output

The safety-related function at the output is dependent on the position of switch DIP1.

- I = Normal In the event of a 0-signal (NAMUR sensor operation high resistance, therefore lower current in the input circuit) the output (N/O contact) switches to the "non-conductive" state.
- II = Inverse In the event of a 1-signal at the input, the function output switches to the "non-conductive" state.

9.2 Diagnostic function of switch DIP2

For safety applications, line fault detection is enabled, i.e., the DIP2 switch is in the "II" position.



WARNING: The "DIP 2 = I" switch position is **not permitted** for safety-related applications.

When line fault detection is enabled, the red LED indicates any faults that occur. If a line fault is detected, the output is disabled ("non-conductive"). This behavior is not dependent on the position of the DIP1, DIP3 and DIP4 switches.

9.3 Safe state

The "safe state" means that the output is in a non-conductive state, i.e., the relay contact is open.

9.4 Response times

Following a state change at the input, the output enters the safe state in ≤ 40 ms.

9.5 Operating mode of the safety function

Operating mode as per EN 61508: "Low demand mode"

9.6 Failure behavior and required response

1. The safe state is entered in the event that a line fault is detected or the supply voltage fails (see Section 9.3).
2. The safe state is reached by removing the connection terminal blocks.

Startup and restart

| Behavior | Description |
|---|--|
| Startup or restart of the device | The output enters the state without oscillation (according to the truth table on page 9). A reset is not required. |
| What happens when a line fault is detected and what must the user do? | The fault is indicated by the red LED and the output enters the "non-conductive" state regardless of the input signal and the operating mode (normal or inverse mode). The user must remove the line fault (short circuit or break in the sensor cable). The device output is not blocked when fault detection is triggered (no lock or reset). Undefined line states that occur during repairs can switch the output. The user must prevent this from happening by disconnecting the supply voltage or removing the connection terminal blocks. Other options that have the same result and do not present an additional hazard are permitted. |
| The line fault is removed. | The user must ensure that a defined state is entered using the truth table on page 9. The device is restarted in the same way as during initial startup. The device then behaves as described under "Startup or restart of the device". |

9.7 Safety integrity requirements

Failure rates

- Type A device (according to EN 61508-2)
- Safety Integrity Level (SIL) 1 and 2

Non-inverted operation:

| λ_{sd} | λ_{su}^* | λ_{dd} | λ_{du} | SFF [†] | DC _S [‡] | DC _D [‡] |
|---------------------|------------------|----------------|----------------|------------------|------------------------------|------------------------------|
| 6 FIT ^{**} | 249 FIT | 7 FIT | 64 FIT | 78% | 2.4% | 9% |

* The SU (Safe Undetected) category includes failures that do not cause a spurious trip.

† SFF = Safe Failure Fraction

‡ DC = Diagnostic Coverage (safe or dangerous)

** FIT = Failure in Time (1 FIT = 1 failure/10⁹ h)

PFD_{AVG} values

| T[PROOF] = | 1 year | 2 years | 5 years |
|----------------------|----------|----------|----------|
| PFD _{AVG} = | 3.09E-04 | 6.17E-04 | 1.54E-03 |

* PFD = Probability of Failure on Demand

Inverted operation:

| λ_{sd} | λ_{su}^* | λ_{dd} | λ_{du} | SFF [†] | DC _S [‡] | DC _D [‡] |
|---------------------|------------------|----------------|----------------|------------------|------------------------------|------------------------------|
| 1 FIT ^{**} | 248 FIT | 6 FIT | 62 FIT | 78% | 0.4% | 8% |

* The SU (Safe Undetected) category includes failures that do not cause a spurious trip.

† SFF = Safe Failure Fraction

‡ DC = Diagnostic Coverage

** FIT = Failure in Time (1 FIT = 1 failure/10⁹ h)

PFD_{AVG} values

| T[PROOF] = | 1 year | 2 years | 5 years |
|----------------------|----------|----------|----------|
| PFD _{AVG} = | 3.01E-04 | 6.02E-04 | 1.50E-03 |

* PFD = Probability of Failure on Demand

The boxes marked in white mean that the calculated PFD_{AVG} values are within the allowed range for SIL 2 according to table 2 of EN 61508-1, but do not fulfill the requirement to not claim more than 10% of this range, i.e., to be better than or equal to 1.00E-03.

The boxes marked in gray mean that the calculated PFD_{AVG} values are within the allowed range for SIL 2 according to table 2 of EN 61508-1, and do fulfill the requirement to not claim more than 10% of this range, i.e., to be better than or equal to 1.00E-03.

Failure limit

The operating mode is based on low demand mode. The percentage of the device at PFH/PFD for the overall safety loop is less than 10%.




Figure 7 Safety loop

Conditions

- The failure rates of the components used remain constant throughout the period of use.
- Propagation of errors by the device in the system is not taken into consideration.
- The repair time (= replacement) should take eight hours.
- The failure rates of the external power supply are not taken into consideration.
- The average temperature at which the device is to be used is +40°C. This is based on standard industrial conditions.

The failure rates given refer to an ambient temperature of +40°C. For an ambient temperature of +60°C, you will need to multiply the failure rates by a factor of 2.5. The factor of 2.5 is based on empirical values gathered.

9.8 Proof test

1. Carry out the appropriate steps to prevent incorrect use.
2. An appropriate signal is applied at the input of the MACX MCR-EX-SL-NAM-2RO in order to obtain the non-conductive state at the output. Check whether the output is non-conductive.
3. Restore the safety circuit to full functionality.
4. Return to normal operation.

With this test, around 99% of possible "du" ("dangerous undetected") errors are uncovered in the repeater power supply.



Компания «ЭлектроПласт» предлагает заключение долгосрочных отношений при поставках импортных электронных компонентов на взаимовыгодных условиях!

Наши преимущества:

- Оперативные поставки широкого спектра электронных компонентов отечественного и импортного производства напрямую от производителей и с крупнейших мировых складов;
- Поставка более 17-ти миллионов наименований электронных компонентов;
- Поставка сложных, дефицитных, либо снятых с производства позиций;
- Оперативные сроки поставки под заказ (от 5 рабочих дней);
- Экспресс доставка в любую точку России;
- Техническая поддержка проекта, помощь в подборе аналогов, поставка прототипов;
- Система менеджмента качества сертифицирована по Международному стандарту ISO 9001;
- Лицензия ФСБ на осуществление работ с использованием сведений, составляющих государственную тайну;
- Поставка специализированных компонентов (Xilinx, Altera, Analog Devices, Intersil, Interpoint, Microsemi, Aeroflex, Peregrine, Syfer, Eurofarad, Texas Instrument, Miteq, Cobham, E2V, MA-COM, Hittite, Mini-Circuits, General Dynamics и др.);

Помимо этого, одним из направлений компании «ЭлектроПласт» является направление «Источники питания». Мы предлагаем Вам помощь Конструкторского отдела:

- Подбор оптимального решения, техническое обоснование при выборе компонента;
- Подбор аналогов;
- Консультации по применению компонента;
- Поставка образцов и прототипов;
- Техническая поддержка проекта;
- Защита от снятия компонента с производства.



Как с нами связаться

Телефон: 8 (812) 309 58 32 (многоканальный)

Факс: 8 (812) 320-02-42

Электронная почта: org@eplast1.ru

Адрес: 198099, г. Санкт-Петербург, ул. Калинина, дом 2, корпус 4, литера А.