IB IL 24 PWR IN/PS IB IL 24 PWR IN/PS-PAC

Inline Power Terminal for the System Voltages U_M , U_S , U_L , U_{ANA}

Data Sheet 694500

05/2003



For reasons of simplification the designation IB IL 24 PWR IN/PS will be used in the following.

This data sheet is only valid in association with the "Configuring and Installing the INTERBUS Inline Product Range" User Manual IB IL SYS PRO UM E or the Systems Manual for your bus system.

Function

The terminal supplies an Inline station with voltage if there is no bus terminal. This, for example, applies to the ILC 200 UNI. The terminal is supplied with a 24 V DC voltage (U_{24V}) , from which the communications voltage (U_L) and the supply voltage for the analog terminals (U_{ANA}) are provided. In addition, the 24 V DC main voltage (U_M) and the 24 V DC segment voltage (U_S) can be supplied using the terminal.

Features

 Supplies all 24 V DC voltages required for the low-level signal of an Inline station

6945A001

 Diagnostic indicators (state of the supply voltages)



Figure 1 IB IL 24 PWR IN/PS terminal with connectors

```
R
```

The terminal interrupts diagonal routing and the bus connection and is thus only to be used at the beginning of an Inline station.





Figure 2 IB IL 24 PWR IN/PS with appropriate connectors



Connectors 1 and 2 are not used.

Local Diagnostic Indicators

Des.	Color	Meaning
UL	Green	7.5 V communications power
US	Green	24 V segment supply
UM	Green	24 V main supply



Terminal Point	Assignment		Remark
Connector 3	24 V Supply for Generating U _L and U _{ANA}		
1.1, 2.1			Not used
1.2, 2.2	24 V DC	U _{24 V}	24 V supply for generating U_L and U_{ANA}
1.3, 2.3	GND	GND	GND of the 24 V supply
1.4, 2.4	FE	Functional earth ground	Grounding of the power terminal and therefore of the Inline station. The contacts are directly connected to the potential jumper and the FE spring on the bottom of the housing. Functional earth ground is only used to discharge interference.
Connector 4	Power Connector for U_S and U_M		
1.1, 2.1	24 V DC	U _S	24 V segment supply The supplied voltage is directly led to the potential jumper.
1.2, 2.2	24 V DC	U _M	24 V main supply The supplied voltage is directly led to the potential jumper.
1.3, 2.3	GND	Reference potential	The reference potential is directly led to the potential jumper and is, at the same time, ground reference for the main and segment supply.
1.4, 2.4	FE	Functional earth ground	Grounding of the power terminal and therefore of the Inline station. The contacts are directly connected to the potential jumper and the FE spring on the bottom of the housing. Functional earth ground is only used to discharge interference.

Terminal Point Assignment for Connectors 3 and 4



Observe the current carrying capacity

The maximum total current of the potential jumpers $U_{\rm M}$ and $U_{\rm S}\,$ is 8 A.



Ground the power terminal

Connect the power terminal to functional earth ground (FE) via one of the FE connections of connector 3 or connector 4. For this, connect the corresponding contact with a grounding terminal (see also Figure 4 on page 6).



24 V Segment Supply/24 V Main Supply

The segment supply and main supply must have the same reference potential. Therefore, an electrically isolated voltage area on the I/O side cannot be created.

The main supply and the segment supply are protected against polarity reversal and transient surge voltage.



Ensure short circuit protection!

The main supply and the segment supply do not have short-circuit protection.

The user must provide short-circuit protection. The rating of the preconnected fuse must be such that the maximum permissible load current is not exceeded.

24 V Segment Supply

You can provide the segment supply at the IB IL 24 PWR IN/PS terminal or one of the supply terminals.

There are several ways of providing the segment voltage at the IB IL 24 PWR IN/PS terminal (connector 4):

- 1. You can provide the segment supply separately at terminal points 1.1 (or 2.1) and 1.3 (or 2.3) (GND) of the power connector (Figure 4 on page 6).
- 2. You can jumper connections 1.1 (or 2.1) and 1.2 (or 2.2) to tap the supply for the segment circuit from the main circuit.
- 3. You can insert a switch between terminal points 1.1 (or 2.1) and 1.2 (or 2.2) to create a switched segment circuit (e.g., an emergency stop circuit).

24 V Supply for Generating U_L and U_{ANA}

The 24 V supply is protected against polarity reversal and surge voltage. These protective elements are only used to protect the power supply unit.



Ensure short circuit protection!

The 24 V supply does not have short-circuit protection.

The user must provide short-circuit protection. The rating of the preconnected fuse must be such that the maximum permissible load current is not exceeded.



Internal Circuit Diagram



Figure 3 Internal wiring of the terminal points

\$*

LED with function identification



Electrically isolated area



Converter

- $\mathbf{1}$ Diode
- Reference potential GND 1 (24 V supply)



Other symbols used are explained in the IB IL SYS PRO UM E User Manual.



Connection Example



Figure 4 Typical connection of the cables to the power terminal



Technical Data

28 19 46 4			
20 10 40 4			
AC 28 63 13 5			
48.8 mm x 120 mm x 71.5 mm (1.921 in. x 4.724 in. x 2.815 in.)			
132 g (without connectors)			
-25°C to +55°C (-13°F to +131°F)			
-25°C to +85°C (-13°F to +185°F)			
75% on average, 85% occasionally			
In the range from -25°C to +55°C (-13°F to +131°F) appropriate measures against increased humidity (> 85%) must be taken.			
Permissible humidity (storage/transport)75% on average, 85% occasionally			
For a short period, slight condensation may appear on the housing if, for example, the terminal is brought into a closed room from a vehicle.			
80 kPa to 106 kPa (up to 2000 m [6562 ft.] above sea level)			
70 kPa to 106 kPa (up to 3000 m [9843 ft.] above sea level)			
IP 20 according to IEC 60529			
Class 3 according to VDE 0106, IEC 60536			



24 V Main Supply/24 V Segment Supply		
Connection	Through power connector; Terminal point assignment see page 3	
Connection method	Spring-cage terminals	
Recommended cable lengths	30 m (98.43 ft.), maximum; routing cables through outdoor areas is not permissible	
Voltage continuation	Through potential routing	
Special demands on the voltage supply	When supply voltages U_M/U_S are supplied separately from supply voltage U_{24V} , they are electrically isolated from one another. This is only possible when using two separate power supply units.	
Response when voltage dips and interrupts occur	Voltages (main and segment supply) that are transferred from the power terminal to the potential jumpers follow the supply voltages without delay.	
Nominal value	24 V DC	
Tolerance	-15%/+20% (according to EN 61131-2)	
Ripple	± 5%	
Permissible range	19.2 V to 30 V	
Current carrying capacity	8 A, maximum	
Safety equipment		
Surge voltage	Yes	
Polarity reversal	Yes	



Provide an external fuse for the 24 V area

This 24 V area must be externally protected. The power supply unit must be able to supply four times the nominal current of the external fuse, to ensure that the fuse blows in the event of an error.



24 V Supply for Generating U _L and U _{ANA}		
Connection	Through connector; Terminal point assignment see page 3	
Connection method	Spring-cage terminals	
Recommended cable lengths	30 m (98.43 ft.) maximum; routing cables through outdoor areas is not permissible	
Voltage continuation	Through potential routing	
Special demands on the voltage supply	When supply voltage U_{24V} is supplied separately from supply voltages U_M/U_S , they are electrically isolated from one another. This is only possible when using two separate power supply units.	
Nominal value	24 V DC	
Tolerance	-15%/+20% (according to EN 61131-2)	
Ripple	± 5%	
Permissible range	19.2 V to 30 V	
Minimum current consumption at nominal voltage	0.012 A DC	
Maximum current consumption at nominal voltage	1.25 A DC consisting of:0.75 A DC for communications power0.5 A DC for analog voltage supply	
Safety equipment	Only for the 24 V supply	
Surge voltage	Yes	
Polarity reversal	Yes	



Provide an external fuse for the 24 V area

This 24 V area must be externally protected. The power supply unit must be able to supply four times the nominal current of the external fuse, to ensure that the fuse blows in the event of an error.

24 V Module Supply		
Communications Power (Potential Jumper)		
Nominal value	7.5 V DC	
Tolerance	± 5%	
Ripple	± 1.5%	
Maximum output current	2 A DC	
Safety equipment	Electronic short-circuit protection	
Analog Supply (Potential Jumper)		
Nominal value	24 V DC	
Tolerance	- 15% / + 20%	
Ripple	± 5%	
Maximum output current	0.5 A DC	
Safety equipment	Electronic short-circuit protection	

Power Dissipation

Formula to Calculate the Power Dissipation of the Electronics

$$P_{EL} = (1.1 \frac{W}{A} x_{n=1}^{a} I_{Ln}) + (0.7 \frac{W}{A} x_{m=1}^{b} I_{Lm})$$

Where P _{EL}	Total power dissipation in the terminal
l _{Ln} n a	Current consumption of the device n from the communications power Index of the number of connected devices (n = 1 to a) Number of connected devices (supplied with communications voltage)
$\sum_{n=1}^{a} I_{Ln}$	Total current consumption of the devices from the 7.5 V communications power (2 A, maximum)
l _{Lm} m b	Current consumption of the device m from the analog supply Index of the number of connected analog devices (m = 1 to b) Number of connected analog devices (supplied with analog voltage)
$\sum_{m=1}^{b} I_{Lm}$	Total current consumption of the devices from the 24 V analog power (0.5 A, maximum)



Power Dissipation (Continued)

Using the maximum currents 2 A (logic current) and 0.5 A (current for analog terminals) in the formula to calculate the power dissipation when the I/O is connected gives the following result:

 $P_{EL} = 2.2 \text{ W} + 0.35 \text{ W} = 2.55 \text{ W}$

Error Messages to the Higher-Level Control or Computer System

None

Safety Equipment		
Surge voltage (segment supply/main supply/24 V supply)	Input protective diodes (can be destroyed by permanent overload)	
	Pulse loads up to 1500 W are short circuited by the input protective diode.	
Polarity reversal (segment supply/main supply)	Parallel diodes against polarity reversal; in the event of an error the high current through the diodes causes the preconnected fuse to blow.	
Polarity reversal (24 V supply)	Serial diode in the lead path of the power supply unit; in the event of an error only a low current flows. In the event of an error the fuse in the external power supply unit does not trip.	



If you want to protect the supply U_{24V} , use a 2 A medium blow fuse.

Electrical Isolation/Isolation of the Voltage Areas		
Common Potentials		
When providing the 24 V supply for generating U_L and U_{ANA} separately from the 24 V main supply/24 V segment supply	Main supply and segment supply have the same potential. From the power terminal onwards, common ground is led through the potential jumper to the devices as reference ground GND. 24 V supply for generating U_L and U_{ANA} , 24 V analog supply and 7.5 V communications power have the same potential. From the bus terminal onwards, common ground is led through the potential jumper to the devices as reference ground "logical GND" (U_L .).	
When providing the 24 V supply for generating U _L and U _{ANA} by jumpering the 24 V main supply/24 V segment supply	Main supply, segment supply, 24 V analog supply, and 7.5 V communications power have the same potential. From the power terminal onwards, common ground is led through the potential jumper to the devices as reference ground "logical GND" (U_{L-}) for the communications power and analog supply and separately as reference ground GND for the supply and segment level.	
Separate Potentials		
When providing the 24 V supply for generating U_L and U_{ANA} separately from the 24 V main supply/24 V segment supply	The 24 V supply for generating U _L and U _{ANA} is physically and therefore electrically isolated from the main supply and segment supply.	
When providing the 24 V supply for generating U_L and U_{ANA} by jumpering the 24 V main supply/24 V segment supply	None	



Electrical Isolation/Isolation of the Voltage Areas			
Test Distance	Test Voltage		
7.5 V communications power, 24 V analog supply/ functional earth ground	500 V AC, 50 Hz, 1 min		
7.5 V communications power, 24 V analog supply/ 24 V main supply, 24 V segment supply	500 V AC, 50 Hz, 1 min		
24 V main supply, 24 V segment supply/ functional earth ground	500 V AC, 50 Hz, 1 min		

Ordering Data

Description	Order Designation	Order No.
Inline power terminal for the system voltages U_M , U_S , U_L , U_{ANA} including connectors and labeling fields	IB IL 24 PWR IN/PS-PAC	28 63 13 5
Inline power terminal for the system voltages U_M , U_S , U_L , U_{ANA}	IB IL 24 PWR IN/PS	28 19 46 4
Connector set with all necessary connectors for the terminal	IB IL PWR IN/R-PLSET	28 60 62 0
"Configuring and Installing the INTERBUS Inline Product Range" User Manual	IB IL SYS PRO UM E	27 43 04 8



Phoenix Contact GmbH & Co. KG Flachsmarktstr. 8 32825 Blomberg Germany



+ 49 - (0) 52 35 - 3-00

+ 49 - (0) 52 35 - 3-4 12 00

www.phoenixcontact.com

Worldwide Locations: www.phoenixcontact.com/salesnetwork





Компания «ЭлектроПласт» предлагает заключение долгосрочных отношений при поставках импортных электронных компонентов на взаимовыгодных условиях!

Наши преимущества:

- Оперативные поставки широкого спектра электронных компонентов отечественного и импортного производства напрямую от производителей и с крупнейших мировых складов;
- Поставка более 17-ти миллионов наименований электронных компонентов;
- Поставка сложных, дефицитных, либо снятых с производства позиций;
- Оперативные сроки поставки под заказ (от 5 рабочих дней);
- Экспресс доставка в любую точку России;
- Техническая поддержка проекта, помощь в подборе аналогов, поставка прототипов;
- Система менеджмента качества сертифицирована по Международному стандарту ISO 9001;
- Лицензия ФСБ на осуществление работ с использованием сведений, составляющих государственную тайну;
- Поставка специализированных компонентов (Xilinx, Altera, Analog Devices, Intersil, Interpoint, Microsemi, Aeroflex, Peregrine, Syfer, Eurofarad, Texas Instrument, Miteq, Cobham, E2V, MA-COM, Hittite, Mini-Circuits, General Dynamics и др.);

Помимо этого, одним из направлений компании «ЭлектроПласт» является направление «Источники питания». Мы предлагаем Вам помощь Конструкторского отдела:

- Подбор оптимального решения, техническое обоснование при выборе компонента;
- Подбор аналогов;
- Консультации по применению компонента;
- Поставка образцов и прототипов;
- Техническая поддержка проекта;
- Защита от снятия компонента с производства.



Как с нами связаться

Телефон: 8 (812) 309 58 32 (многоканальный) **Факс:** 8 (812) 320-02-42 **Электронная почта:** <u>org@eplast1.ru</u> **Адрес:** 198099, г. Санкт-Петербург, ул. Калинина, дом 2, корпус 4, литера А.